

## SECTION 600 -- PLUMBING

## A. GENERAL

1. Every Specification Section is required to include in Part 2 (as the first item), “SUBSTITUTIONS: Materials shall be as specified...” (refer to “SECTION 100 -- GENERAL” for the entire statement).
2. Make sure all specification sections are coordinated with the Bureau’s General Conditions, Document 000708.
3. Penetration Firestopping: Provide penetration firestopping in fire-resistance-rated walls, horizontal assemblies, and smoke barriers in accordance with building and fire code requirements. Firestop systems will be UL Classified to ASTM E814 (UL 1479). Submittals are required, including for product data, product schedule, qualification data, and product test reports (with locations).
  - a. Projects with Architect: Firestopping specifications are required in Division 7. Include requirement for firestopping in fire sprinkler, plumbing, hvac, electrical, and communications specification sections with reference to the firestopping specification located in Division 7.
  - b. Projects with Engineer (and no Architect): For fire sprinkler, plumbing, hvac, electrical, and communication projects where there is no Architect involved in the project, firestopping specifications are required and may be located in and are required to be coordinated with all corresponding specification sections.
4. Additional guidelines: Refer to “SECTION 700 -- MECHANICAL.”