

STATE OF NEW HAMPSHIRE
BUREAU OF PURCHASE AND PROPERTY
STATE HOUSE ANNEX
25 CAPITOL STREET
CONCORD, NEW HAMPSHIRE 03301-6398

ADDENDUM #1 TO RFP NO. 2015-176

DATE OF BID OPENING: 8/26/2015

TIME OF BID OPENING: 12:00 NOON

FOR: Performance Contracting Services for 28 Buildings in Concord, NH

CLARIFY THE FOLLOWING INFORMATION:

- Link to current woodchip contract (for informational purposes only):
<http://www.admin.state.nh.us/purchasing/Notice%20of%20Contract%20SIGNED/8001419%20Bulk%20Wood%20Chips.pdf>
- Please see the language below regarding natural gas pipeline work:

Regulated Natural Gas Delivery Pressure:

The standard delivery pressure for Liberty Utilities is 7" of water column. The bidder is responsible for sizing all after meter gas piping to ensure proper equipment operation with the standard delivery pressure. Liberty Utilities will provide elevated pressure after the meter only if the equipment requires the elevated pressure for proper operation. Gas piping designs that specify elevated pressure (any pressure above 13.8" w.c. according to NH PUC Chapter 500, Part 504.03) will not be guaranteed the specified operating pressure unless approved by Liberty Utilities prior to bid submittal. Please contact Liberty Utilities to review gas piping designs that specify elevated pressure.

Liberty Utilities Contact Information: Andy Morgan, Account Manager – Email: Andrew.Morgan@libertyutilities.com, Phone: (603)782-2321.

- See new attachments:
 - RFP #2015-176 (redline version to show changes)
 - Attachment A – revised
 - Forms E-2 and E-3 Access Database – revised
 - Instructions for Forms E-2 and E-3 – revised)
 - Q&A, Pre-Bid Conference 6/25/15
 - Sign-in Sheets, Pre-Bid Conference 6/25/15
 - NH Hospital Contractor Safety Guidelines

BID CONTACT: Karen Rantamaki, P.E.

TEL. NO.: 603/271-2698

NOTE: IN THE EVENT THAT YOUR BID INVITATION HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

BIDDER _____ ADDRESS _____

BY _____
(this document must be signed)

_____ TEL. NO. _____
(please type or print name)