

STATE OF NEW HAMPSHIRE
BUREAU OF PURCHASE AND PROPERTY
STATE HOUSE ANNEX
25 CAPITOL STREET
CONCORD, NEW HAMPSHIRE 03301-6398

ADDENDUM # 1 TO BID INVITATION # 212 -16

DATE OF BID OPENING: 5/09/16

TIME OF BID CLOSING: 1:30 PM (EST)

FOR: UPS Batteries - Supply & Install

Clarification:

Q1: Curious if the batteries can be installed during regular business hours.

A1: Installation can be done during regular business hours, but will need to be scheduled with the agency prior to any work being started to insure availability of the conference room that abuts the UPS room.

Q2: Also can an alternative battery, EnerSys, be used?

A2: The agency has reached out to the manufacture of the UPS unit and the manufacturer recommends a direct replacement. So the answer is no on an alternative battery being used.

Currently Reads:

The manufacturer(s) and/or model(s) indicated in this bid are equivalent to the type and quality required. You may bid different make(s) and model(s); however, your offer must match or exceed the one(s) indicated and you must demonstrate to the satisfaction of the purchasing Agency that they meet or exceed the minimum standards. Items that don't meet the minimum standards will not be accepted. Product literature and specifications may be enclosed.

Change to Read:

The manufacturers and/or product numbers indicated are the only ones that are acceptable under this bid invitation.

PURCHASING AGENT: Paul Rhodes

TEL. NO.: 603/271- 3350

NOTE: IN THE EVENT THAT YOUR BID INVITATION HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

BIDDER _____ **ADDRESS** _____

BY _____

(this document must be signed)

_____ **TEL. NO.** _____

(please type or print name)

Please visit: <http://das.nh.gov/purchasing>
(click on "Bid, Proposals...") for complete bid and addendums.