

STATE OF NEW HAMPSHIRE

BUREAU OF PURCHASE AND PROPERTY
STATE HOUSE ANNEX
25 CAPITOL STREET
CONCORD, NEW HAMPSHIRE 03301-6398

ADDENDUM # 1

TO RFB INVITATION # 255-15

DATE OF BID OPENING: 6/17/15

TIME OF BID OPENING: 11:30 AM

FOR: ALUMINUM ENTRY DOORS – SUPPLY & INSTALL

QUESTIONS & ANSWERS

QUESTION #1

Are both door leafs going to have vertical top and bottom rods or just the semi active door and just surface mounted rim panic on active door, also the specs on the bid calls for first choice rim panic exit devices and Norton closers. I believe these specs pertain to the aluminum entrance originally spec'd . The second set of doors have Von Duprin rim panic with concealed vertical top and bottom rods which are electrified on the active door, the semi active door has Von Duprin rim panic with concealed vertical top and bottom rods but is not electrified. My recommendation is to use a LCN door closer which is heavier duty door closer which would work better for the steel doors.

ANSWER #1

See revised Response Table

CHANGE: BID INVITATION NAME

FROM: ALUMINUM ENTRY DOORS – SUPPLY & INSTALL

TO: COMMERCIAL STEEL ENTRY DOORS – SUPPLY & INSTALL

CHANGE: DATE OF BID OPENING

FROM: 6/15/15

TO: 6/17/15

DELETE THE ORIGINAL PRICE RESPONSE TABLE AND REPLACE WITH THE FOLLOWING:

Line Item	Qty	Unit of Measure	Description	Unit Price	Extended Price
1	2	Each	Commercial Steel double entrance doors as described at Site Visitation. Vistawell or equal narrow style double door and frame, butt hinges, Exposed rods top only on inactive door, no rods on active door, green surface, Van Duprin panic exit devices on both doors, pull handle, Norton closures or equal. 6" X 24" vertical light in each door. Light doesn't have to be exactly 6"X24" but should be as close to that size as possible. Heavy duty threshold Remove and dispose of old doors.		
2	2	Each	Electrical work as needed for electric strikes. Electric Strikes in panic device on active door.		
3	2	Each	Installation		
				TOTAL	

PURCHASING AGENT: **ROBERT LAWSON**
TEL. NO.: **603/271-3147**

NOTE: IN THE EVENT THAT YOUR BID INVITATION HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

BIDDER _____ ADDRESS _____

BY _____

(this document must be signed)

_____ TEL. NO. _____

(please type or print name)