

STATE OF NEW HAMPSHIRE

BUREAU OF PURCHASE AND PROPERTY
STATE HOUSE ANNEX
25 CAPITOL STREET
CONCORD, NEW HAMPSHIRE 03301-6398

ADDENDUM # 1

TO RFB INVITATION # 513-12

DATE OF BID OPENING: 4/6/12

TIME OF BID OPENING: 11:30 AM

FOR: CORD REELS AND INSTALL

QUESTIONS AND ANSWERS

QUESTION #1

Is this job a rated job that must comply with Davis-Bacon wage rates?

ANSWER #1

No, bids need not comply with Davis-Bacon wage rates.

QUESTION #2

Will the lifts being powered up be 3-phase, 4-wire (3-hots and a ground);

ANSWER #2

Yes

QUESTION #3

Is the equipment voltage to be 208-volts, 3-phase;

ANSWER #3

Power requirement 208/ 30A/ 3 ph.

QUESTION #4

How long should the cord be on each reel;

ANSWER #4

25' +/-

QUESTION #5

Is there a set location for each reel, ie, middle of each of 4-bays?

ANSWER #5

Yes, 1 reel between each bay on or about the bar joist for 3 and 1 reel in the rear to service the back bay. Plan to carry the cost of a little unistrut for adjustments

PURCHASING AGENT: **ROBERT LAWSON**
TEL. NO.: **603/271- 3147**

NOTE: IN THE EVENT THAT YOUR BID INVITATION HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

BIDDER _____ ADDRESS _____

BY _____
(this document must be signed)

_____ TEL. NO. _____
(please type or print name)