

STATE OF NEW HAMPSHIRE
BUREAU OF PURCHASE AND PROPERTY
STATE HOUSE ANNEX
25 CAPITOL STREET
CONCORD, NEW HAMPSHIRE 03301-6398

ADDENDUM #2 TO BID INVITATION #247-14

DATE OF BID OPENING: 5/15/2014

TIME OF BID OPENING: 1:30pm (EST)

FOR: Swing Gates

CHANGE THE FOLLOWING INFORMATION.

CURRENTLY READS:

1. Date of Bid Opening: 05/12/14

CHANGE TO READ:

1. Date of Bid Opening: 05/15/14

Question #1

Please specify the material and dimensions required for the "Dead Man" stabilizer and also the "Lock Protector". If you have details you could supply it would be very helpful."

Answer #1

On the last batch of gates we used 1-1/2" schedule 40 pipe x 12" long
The lock protector was fabricated using 3/16" thick steel plate.

Question #2

If you be so kind to provide me with the specifications of the size and or gage of the metal you used for this stuff I would appreciate your effort.

Answer #2

All of the pipes used on this project are schedule 40 approx. 3/16" thick.

PURCHASING AGENT: Laura Ingram

TEL. NO: 603/271-2201

FAX No: 603-271-7564

E-Mail: PRCHWEB@NH.GOV

NOTE: IN THE EVENT THAT YOUR BID INVITATION HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

BIDDER _____ ADDRESS _____

BY _____ TEL. NO. _____

(this document must be signed)

Please visit: WWW.Admin.State.NH.US/Purchasing/Vendorresources.ASP

(click on "Bid, Proposals...") for complete bid and addendums.