

STATE OF NEW HAMPSHIRE
 BUREAU OF PURCHASE AND PROPERTY
 STATE HOUSE ANNEX
 25 CAPITOL STREET
 CONCORD, NEW HAMPSHIRE 03301-6398

ADDENDUM #3 TO BID INVITATION #365-13

FOR: Wood Boilers

PLEASE CHANGE THE FOLLOWING:

CHANGE #1:
Please add the following to the offer section:

Quantity	Unit	Description	Unit Price	Total Delivered Price
Londonderry Site				
1	EA	Unit Heater	\$	\$

CLARIFICATION:

Q1. The way the documents for pricing states, we are only supplying the materials to be delivered to the site. Off loading, setting and everything else would be by others, this is how *I am reading the bid documents*. If this is not the case you may want to make this clear.

A1. If the agency receives a minimum 24 hour notification then DOT will unload materials. Otherwise is shall be the contractor's responsibility.

Q2. 2.2-Unit Heater for Londonderry; A. Modine model no. "PT/PTN"; need to choose either "PT" or "PTN", these are two different coil options, "PT" is for a copper tube coil and "PTN" is for a cupro/nickel tube coil....

A2. Please change to PT

PURCHASING AGENT: Melanie Carraher

TEL. NO: 603/271-3146

E:Mail: Melanie.Carraher@nh.gov

NOTE: IN THE EVENT THAT YOUR BID INVITATION HAS BEEN SENT TO THIS OFFICE PRIOR TO RECEIVING THIS ADDENDUM, RETURN ADDENDUM WITHIN THE SPECIFIED TIME WITH ANY CHANGES YOU MAY WISH TO MAKE AND MARK ON THE REMITTANCE ENVELOPE BID INVITATION NUMBER AND OPENING DATE. RETURNED ADDENDA WILL SUPERSEDE PREVIOUSLY SUBMITTED BID.

BIDDER _____ ADDRESS _____

BY _____
 (this document must be signed)

_____ TEL. NO. _____
 (please type or print name)

Please visit: WWW.Admin.State.NH.US/Purchasing/Vendorresources.ASP
 (click on "Bid, Proposals...") for complete bid and addendums.